



Test certificate

NO.:CNCE/T-10007

(Test report no.:DY090807)

Manufacturer: Zhejiang Yuebian Transformer Co., Ltd

Item name: Power transformer

Model no.: S11-M-800/10

Serial no.: 200910025

Test project: Routine test, Heating test, sound level test, 3-phase transformer zero sequence impedance test, no load current harmonics test, short circuit withstand test, lightning impulse test.

Test standard: GB1094.1-1996, GB1094.2-1996, GB1094.3-2003, GB1094.5-2008, GB/T1094.10-2003, GB/T6451-2008

Test result: The result of the power transformer(No.:S11-M-800/10)'s routine test, heating test, sound level test, 3-phase transformer zero sequence impedance test, no load current harmonics test, short circuit withstand test, lightning impulse test meet the requirement of the test standard and delegation's technical requirement, the above test of the sample are qualified.

Date of the certification: 2010-01-06

Expiry date: 5 years

Approval:

林应力



国家中低压输配电设备质量监督检验中心

证书查询网址: www.cnce.asia